


Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by NG. SOBITA DEVI EXECUTIVE ENGINEER (Name of Officers with designation) from IMPHAL WEST PHED DEVISION, MANIPUR inspected the KENDRIYA VIDYALAYA IMPHAL NO. 2 CRPF, LANGJING, IMPHAL WEST, MANIPUR (Name & Address of the school) on 27/10/2023 (date of inspection) and on the basis of Water Test Report (Attached) bearing no DLIW/PHED/2023/151 dated 30/11/2023 of DISTRICT LAB IMPHAL WEST PHED, GOVT. OF MANIPUR certified that the KENDRIYA VIDYALAYA IMPHAL NO. 2 CRPF, LANGJING, IMPHAL WEST, MANIPUR (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. This certificate is valid till 30/11/2024


Executive Engineer
Imphal West PHE Division
PHED, Manipur

Signature with Seal:

Name : NG. SOBITA DEVI

Designation : EXECUTIVE ENGINEER

Name & Address
of the

Office / Department : DISTRICT LAB IMPHAL WEST
PHED, GOVT. OF MANIPUR

To

PRINCIPAL
KENDRIYA VIDYALAYA IMPHAL
NO. 2 CRPF, LANGJING, IMPHAL
WEST, MANIPUR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT LAB IMPHAL WEST PHED, GOVT. OF MANIPUR

FF-13
DLIW/PHED, Manipur
Page No. 1/1

Lamphepat-795004 Email: dliwphed@gmail.com Dr. Ashutosh Singh Principal Kendriya Vidyalaya Imphal No. 2 GC CRPF, Langjing		TEST REPORT Report No. DLIW/PHED/2023/151 Date of Report: 30/10/2023 Sample ID: 2/10 Date of Collection of Sample: 27/10/2023 Duration of Performance: 27/10/2023 Ref No: Nil Date of issue: 30/10/2023	
1	Description of Sample (As declared by customer)	Water	
2	Sample Mark (if any, given by the customer)	NA	
3	Date of Sampling by the Customer	27/10/2023	
4	Source & Place of Sampling	Treated Water	
5	Environmental conditions during sampling	NA	
6	Sampling Plan & Procedures used	NA	
7	Quantity of Water	1 Liter in Plastic Jerrican bottle	
We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results			

Analysis Results (As per IS10500:2012)

Chemical Testing

Sl. No.	Characteristic	Acceptable Limit	Permissible Limit	Method of Test	Results			
					I	NA	NA	NA
1	Chloride (as Cl) in mg/l	250	1000	APHA 23 rd Edition 4500-Cl ⁻ B	18.00			
2	Total Dissolved Solids in mg/l	500	2000	APHA 23 rd Edition 2540 C	78.8			
3	Total Alkalinity in mg/l as CaCO ₃	200	600	APHA 23 rd Edition 2320 B	68.00			
4	Calcium (as Ca) in mg/l	75	200	APHA 23 rd Edition 3500 - Ca B	14.4			
5	Magnesium (as Mg) in mg/l	30	100	APHA 23 rd Edition 3500 Mg B	8.75			
6	pH value at 25°C	6.5-8.5	No Relaxation	APHA 23 rd Edition 4500-H ⁺ B	7.10			
7	Turbidity in NTU	1	5	APHA 23 rd Edition 2130 B	1.00			
8	Total Hardness in mg/l as CaCO ₃	200	600	APHA 23 rd Edition 2340 C	72.00			
*9	Electrical Conductivity in µmho/l			APHA 23 rd Edition 2510 B	148.5			
*10	Iron (as Fe) in mg/l	1.0	No Relaxation	APHA 23 rd Edition 3500-Fe B	0.22			
*11	Fluoride in mg/l as F	1.0	1.5	APHA 23 rd Edition 4500-F ⁻ D	0.52			
*12	Sulphate (as SO ₄) in mg/l	200	400	APHA 23 rd Edition 4500-SO ₄ ²⁻ E	22.00			

* These parameters are not in the scopes of NABL accreditation.

The results relate only to the item(s) tested
This Test Report shall not be reproduced except in full, without the permission of District lab Imphal West PHED, Manipur. The reserved part of sample(s) shall be retained for 7 days from the date of Completion of Test

Prepared by: - H. Bidyarani Devi

Signature 
Designation: Jr. Chemist


Ng. Subita Devi
Executive Engineer
Imphal West PHE Division, Manipur